

DOUBLE DISCONNECT BOARD 2500A DDU-2500A

To be used in conjunction with the standard Double Disconnect control unit:

DDU-CONTROL



- This Double disconnect board is designed for the connection and protection of a PV System with input not exceeding a total of 2500A (990KW)
- This double disconnect unit is controlled by the standard double disconnect control unit which is a standard control unit for all the double disconnect units.
- Once coupled with the double disconnect control unit the connection between the utility grid and the PV Solar system is monitored by an independent grid monitoring relay and can be configured according to the required Country Grid Code for its intended use. A secure grid disconnection is required by series connection of two independently switched air circuit breaker. The switching control is obtained from the Grid Monitoring Relay installed in the control enclosure
- This board is supplied pre-wired with the installer only required to connect the combined output from the PV system, and the Utility side of the installation
- These double disconnect units are delivered with settings already set to suit the South African grid code.
- The enclosure provides excellent protection against the elements.
- Pre-wired internal switchgear improves the system installation time.


Segen Solar (Pty) Ltd Reserves the right to implement changes to specifications depicted in this datasheet to conform to equipment or regulatory requirements

DOUBLE DISCONNECT UNIT

Technical Data

Item Number		DDU-2500A
Inverter Connection		3W+N+E
Circuit breaker current rating –	Adjustable	2500A
Main Output		
Number of inputs		1
Number of Outputs		1
Enclosure material		Mild Steel
Enclosure material thickness		1.6mm
Enclosure Colour		B26 Orange
Door opening	Double Door	Lever Lock
Internal cover plate	Lexan	Yes
Internal components pre-wired		Yes
Panel AC fault level		50kA
System voltage		400V
IP Rating		IP65
Earth Bar		Yes
Dimensions	Height/Width/Depth(mm)	2000 x 1600 x 600
Mounting	Plinth	300 x 1600 x 600
Disconnect type		Air Circuit Breaker

NB: All equipment to be installed and operated by qualified personnel only





245 Masjien Street Strijdom Park, Randburg www.segensolar.co.za

Segen Solar (Pty) Ltd Reserves the right to implement changes to specifications depicted in this datasheet to conform to equipment or regulatory requirements